LICENCE

No. 21044

Issued to:
Applicant:
Legrand Group Belgium N.V.
Kouterveldstraat 9, Ind. Zone
1831 DIEGEM
Belgium

Licensee:
Legrand Group Belgium N.V.
Kouterveldstraat 9, Ind. Zone
1831 DIEGEM
Belgium

Product	:	distribution boards (domestic use)
Trade name(s)	:	LEGRAND
Type(s)/model(s)	:	Series XL³

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 178

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 09/11/2018

ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee

005-PROD

SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	distribution boards (domestic use)
Trade name(s)	:	LEGRAND
Type(s)/Model(s)	:	Series XL³
rated voltage (Un)	:	400 V
nature of supply	:	AC
rated frequency	:	50-60 Hz
rated insulation voltage (Ui)	:	400 V
rated current (In)	:	63 A up to 125 A
number of rows	:	1, 2, 3 and 4
number of modules	:	18, 36, 54 and 72
rated cond. short-circuit withstand current (Icc)	:	smaller or equal than 10 kA rms
protection against electric shock	:	IP30 without door or door open IP40 with door closed
degree of protection	:	IK07

Additional information

See Appendix

TESTS

Test requirements

NBN EN 60670-24 based on EN 60670-24:2013

Test results

The test results are laid down in certification file ref.629133/01

Remarks

This certificate is based on certificate ref. FR-675993 and test report(s) ref. PR003892

Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Silvio Piras - 09/11/2018

Certification Manager :



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

FACTORY LOCATION(S)

Legrand Polska SP. Z O.O.
ul. Warynskiego 20
57200 ZABKOWICE SLASKIE
Poland

Product range

XL³ 125 Cabinets with transparent door (400 V – 50/60 Hz – IP40)

Ref Nr	Height (mm)	Width (mm)	Depth (mm)	# modules	# Row(s)	In (A)
401641	300	450	150	18	1	63
401642	450	450	150	36	2	90
401643	600	450	150	54	3	125
401644	750	450	150	72	4	125

XL³ 125 Cabinets with white door (400 V – 50/60 Hz – IP40)

Ref Nr	Height (mm)	Width (mm)	Depth (mm)	# modules	# Row(s)	In (A)
401631	270	450	150	18	1	63
401632	450	450	150	36	2	90
401633	600	450	150	54	3	125
401634	750	450	150	72	4	125