CERTIFICATE

Issued to:
Applicant:
Fabricación de Material Eléctrico, S.A.
C/Vapor 12-14 (Poligono Industrial La Ferreria)
08110 Montcada I Reixac, Spain

Product	:	Portable socket-outlet, rewirable
Trade name(s)	:	FME
Type(s)/model(s)	:	2101 and 2101-N

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:
- a type test according to the standard IEC 60884-1:2002, IEC 60884-1:2002/A1:2006, IEC 60884-1:2002/A2:2013, UNE 20315-1-1:2017 and UNE 20315-1-2:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 6057594
- the licensee is registered with the number 43117

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 19 March 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-113050

DEKRA Certification B.V.

B.T.M. Holtus
Managing Director

K Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL

PRODUCTS RvA C 001

KEMA KEUR

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	Portable socket-outlet, rewirable
Trade name(s)	:	FME
Type(s)/model(s)	:	2101 and 2101-N
Rated current	:	16 A
Rated voltage	:	250 V~
Degree of protection	:	IP20
Earthing	:	With earthing-contacts
Design	:	Rewirable, with screw terminals
Standard sheet	:	C2a of UNE 20315-1-2
Certification mark	:	Complies with the requirements
Description	:	Body of thermoplastic

TESTS

Test requirements

IEC 60884-1:2002
IEC 60884-1:2002/A1:2006
IEC 60884-1:2002/A2:2013
UNE 20315-1-1:2017
UNE 20315-1-2:2017

Test result

The test results are laid down in DEKRA test file 606434000.

Additional information

The list of components is laid down at test report 6064340.50.

Conclusion

The examination proved that all requirements were met.

Factory location

The factory location is registered with the number 42848.